



Flowcrete Group Limited
Report No. FL 1607-836

Cleanroom[®] Suitable Materials

Flowshield SL

Outgassing VOC (23°C/90°C):
ISO-ACC_m Class -8.7 / tested

FLOORING & COATING

Outgassing Behavior (VOC)

Qualification Certificate

We hereby certify that the material stated above, provided by

Flowcrete Group Limited
Kuala Lumpur, Malaysia

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number FL 1607-836.

The outgassing behavior of Flowshield SL (color: Light gray) at the stated temperatures was investigated according to VDI 2083-17. Based on the outgassing rates determined for the specific surfaces, the following material classification was made for the corresponding contaminant group:

Test temperature	Contaminant group	Specific emission rate [g/m ² s]	ISO-ACC _m Class (x)
23 °C	VOC	1.9 x 10 ⁻⁰⁹	-8.7
90 °C	Amines	not detectable	--
	Organophosphates	not detectable	--
	Siloxanes	not detectable	--
	Phthalates	not detectable	--

Detailed information regarding specific product data such as manufacturing date, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, October 18, 2016

on behalf of 
Frank Bürger, Project manager Fraunhofer IPA

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:

www.tested-device.com.

Please visit www.ipa-csm.com.

DUPLICATE