



Fraunhofer

TESTED[®] DEVICE

Knauf AMF GmbH & Co. KG
AMF Acoustic Range
Report No. KN 1804-1030

Chemical Resistance

Qualification Certificate

This is to certify that the product mentioned above, provided by

Knauf AMF GmbH & Co. KG
Grafenau, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE
bearing the report number KN 1804-1030.

The Chemical Resistance of the AMF Acoustic Range coating
(white) was classified according to ISO 4628-1 and VDI 2083 Part
17 with the following result:

Chemical Resistance			
Hydrogen peroxide 30 %	good	Acetone 100 %	excellent
Sodium hydroxide 5 %	very weak	Elma Clean 10 %	weak
Isopropanol 100 %	excellent	Microbac food 5 %	weak
Sodium hypochlorite 5 %	very weak	Sodosil RA08 5 %	very weak
Ethanol 100 %	excellent	Desifor-forte 5 %	weak

This document only
applies to the named
product in its original state
and is valid for a period of
5 years from the current date
the document was issued.
The document can be verified
under
www.tested-device.com.

Detailed information and
parameters of the test
environment can be found
in the Fraunhofer IPA test
report.

KN 1202-589
Report No. first document

Stuttgart, April 13, 2012
Place, date of first document issued

KN 1804-1030
Report No. current document

Stuttgart, June 28, 2018
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA