



Cleanroom[®] Suitable Materials

Tarkett AB
Report No. TA 1403-699

iQ Natural
Outgassing VOC (23°C/90°C):
ISO-ACC_m class <-9.6 / tested

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated above, provided by

Tarkett AB
Ronneby, Sweden

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TA 1403-699.

iQ Natural (color 287) was tested regarding outgassing at various temperatures according to VDI 2083-17. The tested material obtained the following classification:

| Test temperatures | Family of contaminants | Specific emission rate [g/m ² s] | ISO-ACC _m Class (x) |
|-------------------|------------------------|---|--------------------------------|
| 23 °C / 73 °F | VOC | <2.8 x 10 ⁻¹⁰ | <-9.6 |
| 90 °C / 194 °F | Amines | not detectable | -- |
| | Organo-phosphates | not detectable | -- |
| | Siloxanes | not detectable | -- |
| | Phthalates | not detectable | -- |

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, September 1, 2014

i. A. 
Project manager

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.