



Fraunhofer

TESTED[®] DEVICE

DAMPA ApS
Clip In ST 15 Tex
Report No. DA 1607-837

Chemical Resistance

Qualification Certificate

This is to certify that the product mentioned above, provided by

DAMPA ApS
Tommerup, Denmark

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number DA 1607-837.

The chemical resistance of the ceiling system Clip In 600 x 600 ST 15 Tex (color: RAL 9010) was classified according to ISO 4628-1 and VDI 2083-17 with the following result:

Chemicals	Chemical Resistance	Chemicals	Chemical Resistance
Formalin 37 %	excellent	Peracetic acid 15 %	none
Ammoniac 25 %	excellent	Hydrochloric acid 5 %	none
Hydrogen peroxide 30 %	none	Isopropanol 100 %	excellent
Sulfuric acid 5 %	none	Sodium hydroxide 5 %	none
Phosphoric acid 30 %	none	Sodium hypochlorite 5 %	very weak

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:

www.tested-device.com

DUPLICATE

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, November 7, 2016

on behalf of 
Frank Bürger, Project manager Fraunhofer IPA