



Cleanroom[®] Suitable Materials

ROHDE KG
Report No. RO 1310-674

Finish 435
Outgassing VOC (23°C/90°C):
ISO-ACC_m class -7.2 / tested

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated above, provided by

ROHDE KG
Röttenbach, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RO 1310-674.

Finish 435 (white) was tested regarding outgassing at various temperatures according to VDI 2083-17. The tested material obtained the following classification:

Test temperatures	Family of contaminants	Specific emission rate [g/m ² s]	ISO-ACC _m Class (x)
23 °C / 73 °F	VOC	6.5 x 10 ⁻⁸	-7.2
90 °C / 194 °F	Amines	1.6 x 10 ⁻⁸	--
	Organo-phosphates	not detectable	--
	Siloxanes	not detectable	--
	Phthalates	not detectable	--

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, January 9, 2014

i. A. 
Project manager

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.