



Sika Deutschland GmbH
Report No. SI 1506-767

Cleanroom[®] Suitable Materials

Sikafloor-305 W ESD

Outgassing VOC (23°C/90°C):
ISO-ACC_m Class <-9.6 / tested

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated above, provided by

Sika Deutschland GmbH
Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of
Qualification with the report number SI 1506-767.

Sikafloor-305 W ESD (RAL 7032) was tested regarding outgassing at
various temperatures according to VDI 2083-17. The tested material
obtained the following classification:

Test tem- peratures	Family of contaminants	Specific emissi- on rate [g/m ² s]	ISO-ACC _m Class (x)
23 °C / 73 °F	VOC	<2.8 x 10 ⁻¹⁰	<-9.6
90 °C / 194 °F	Amines	not detectable	--
	Organophosphates	not detectable	--
	Siloxanes	not detectable	--
	Phthalates	not detectable	--

Detailed information regarding specific product data such as date of
manufacture, color, and serial number as well as test environment
and parameters can be obtained from the CSM test report issued by
the Fraunhofer-Gesellschaft.

Stuttgart, December 8, 2015

on behalf of 
Udo Gommel, Project manager Fraunhofer IPA

The validity of this certificate
is temporary indefinite and
limited to the named product.
It can be verified on
www.tested-device.com.

For more CSM information,
please visit www.ipa-csm.com.

DUPLICATE