



StoCretec GmbH
Report No. ST 1902-1095

Cleanroom[®] Suitable Materials

StoFloor CR System 4
Biological Resistance: none

FLOORING & COATING

Single product Biological Resistance

Qualification Certificate

We hereby certify that the material stated above, provided by

StoCretec GmbH
Kriftel, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number ST 1902-1095.

The CSM classification of StoFloor Cleanroom System 4 (StoPox WHG Deck 100), color: RAL 7032, according to biological resistance is based on a worst-case consideration of both procedures A and C. Therefore growth intensity according to ISO 846 and VDI 2083 Part 18 has been transferred to the following classification:

Biological resistance	Growth intensity	Classification
Fungi (Procedure A)	2	good
Bacteria (Procedure C)	5	none
Overall result	5	none

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

ST 1902-1095
Report No. first document
--
Report No. current document

Stuttgart, February 28, 2019
Place, date of first document issued
--
Place, current date

on behalf of
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA