



GERFLOR
Report No. GE 2203-1313

Cleanroom[®] Suitable Materials

MIPOLAM BIOCONTROL CLEAN
Biological Resistance: none

FLOORING & COATING

Single product Biological Resistance

Qualification Certificate

We hereby certify that the material stated above, provided by

GERFLOR
Saint-Paul-Trois-Châteaux, France

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number GE 2203-1313.

The biological resistance of MIPOLAM BIOCONTROL CLEAN (new varnish), color: intense Indigo, regarding to growth intensity was investigated in accordance with ISO 846 and classified with the following result:

Biological resistance	Growth intensity	Classification
Procedure A (resistance to fungi)	5	none
Procedure C (resistance to bacteria)	0	excellent
Overall result	none	

The classification is based on a worst-case consideration of the Procedures A and C.

GE 2203-1313
Report No. first document

--
Report No. current document

Stuttgart, June 17, 2022
Place, date of first document issued

--
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.