



**Fraunhofer**

**TESTED<sup>®</sup>  
DEVICE**

Damitech Co., Ltd.  
Damitech Pod DA0200  
**Report No. DA 1901-1094**

DUPLICATE

Statement of  
Qualification

Single product  
Particle Emission

# Statement of Qualification · Single product

**Customer**  
 Damitech Co., Ltd.  
 504 Stx W-Tower Guro-Dong  
 90, Gyeongin-ro 53-gil  
 08215 Guro-Gu, Seoul  
 Korea

**Component tested**

Category: Energy Supply  
 Subcategory: Cable Systems  
 Product name: Damitech Pod DA0200  
 (manufacturing date: 12/31/2018; color: white; serial number: DA18-1201;  
 batch number: DA18-1231)

## Random sampling of particle emissions (airborne) at representative sites

Standards/Guidelines: ISO 14644-1, -14  
 The norms stated generally refer to the version valid at the time of the tests.

Test devices: Optical particle counter:  
 LasAir II 110 and LasAir III 110 with measuring ranges  $\geq 0.1 \mu\text{m}$ ,  $\geq 0.2 \mu\text{m}$ ,  
 $\geq 0.3 \mu\text{m}$ ,  $\geq 0.5 \mu\text{m}$ ,  $\geq 1.0 \mu\text{m}$  and  $\geq 5.0 \mu\text{m}$

Test environment parameters:

- Cleanroom Air Cleanliness Class (according to ISO 14644-1):..... ISO 1
- Airflow velocity:.....0.45 m/s
- Airflow pattern:..... vertical laminar flow
- Temperature: .....22 °C  $\pm$  0.5 °C
- Relative humidity: ..... 45 %  $\pm$  5 %

Test procedure parameters:

- Bending radius: .....r = 75 mm
- Stroke length:..... s = 820 mm
- Parameter Set 1:..... $v_1 = 0.5 \text{ m/s}$ ;  $a_1 = 1.0 \text{ m/s}^2$
- Parameter Set 2:..... $v_2 = 1.0 \text{ m/s}$ ;  $a_2 = 2.0 \text{ m/s}^2$
- Parameter Set 3:..... $v_3 = 2.0 \text{ m/s}$ ;  $a_3 = 4.0 \text{ m/s}^2$

## Test result / Classification

When operated under the specified test conditions, the Damitech Pod DA0200 is suitable for use in cleanrooms fulfilling the specifications of the following Air Cleanliness Classes according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
$v_1 = 0.5 \text{ m/s}$ ; $a_1 = 1.0 \text{ m/s}^2$	1
$v_2 = 1.0 \text{ m/s}$ ; $a_2 = 2.0 \text{ m/s}^2$	1
$v_3 = 2.0 \text{ m/s}$ ; $a_3 = 4.0 \text{ m/s}^2$	1
<b>Overall result</b>	<b>1</b>

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer Institute for Manufacturing Engineering and Automation IPA

DA 1901-1094  
 Report No. first document

Stuttgart, February 18, 2019  
 Place, date of first document issued

Department of Ultraclean Technology and Micromanufacturing

--  
 Report No. current document

--  
 Place, current date

Nobelstrasse 12  
 70569 Stuttgart  
 Germany

on behalf of   
 Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA