



nora systems GmbH
Report No. NO 2302-1393

Cleanroom[®] Suitable Materials

norament 926 grano
(slightly structured)
Riboflavin Test: weak

FLOORING & COATING

Single product Riboflavin Test

Qualification Certificate

We hereby certify that the material stated above, provided by

nora systems GmbH
Weinheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number NO 2302-1393.

The examination of cleanability of norament 926 grano (color: 5319) was investigated according to VDMA information sheet. The following test result could be provided:

Material tested	Classification
norament 926 grano (slightly structured)	weak

This document only applies to the named product in its original state and is valid for a period of 5 years from the current date the document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

NO 1711-969
Report No. first document
NO 2302-1393
Report No. current document

Stuttgart, February 28, 2018
Place, date of first document issued
Stuttgart, May 17, 2023
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA