



StoCretec GmbH  
Report No. ST 1902-1095

# Cleanroom<sup>®</sup> Suitable Materials

StoFloor CR System 10  
H<sub>2</sub>O<sub>2</sub> Absorption/Desorption: fast

## FLOORING & COATING

### Single product Hydrogen Peroxide Absorption/Desorption

### Qualification Certificate

We hereby certify that the material stated above, provided by

StoCretec GmbH  
Kriftel, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number ST 1902-1095.

The hydrogen peroxide absorption/desorption of StoFloor Cleanroom System 10 (StoPox BBT 200; StoPox WL 150), color: clear, was investigated at the stated test parameters, providing the following test result according to VDI 2083 Part 20:

Ø k-value [min]	Standard deviation [min]	Classification
7.2	1.5	fast

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

ST 1902-1095  
Report No. first document  
--  
Report No. current document

Stuttgart, February 28, 2019  
Place, date of first document issued  
--  
Place, current date

on behalf of  
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA