



StoCretec GmbH  
Report No. ST 1902-1095

# Cleanroom<sup>®</sup> Suitable Materials

StoFloor CR System 4  
Outgassing VOC/SVOC  
ISO-ACC<sub>m</sub> Class -6.7 / -8.1

## FLOORING & COATING

### Single product Outgassing Behavior VOC/SVOC

### Qualification Certificate

We hereby certify that the material stated above, provided by

StoCretec GmbH  
Kriftel, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number ST 1902-1095.

The outgassing behavior of StoFloor Cleanroom System 4 (StoPox WHG Deck 100), color: RAL 7032, at the stated temperatures was investigated according to VDI 2083 Part 17 and ISO 14644-15. Based on the outgassing rates determined for the specific surfaces, the following material classification was made for the corresponding Contaminant Category:

Contaminant Category (x)	SER <sub>a</sub> <sup>1)</sup> 23 °C [g/m <sup>2</sup> s]	SER <sub>a</sub> <sup>1)</sup> 90 °C [g/m <sup>2</sup> s]	ISO-ACC <sub>m</sub> Class (x) based on 23 °C
VOC	2.0 x 10 <sup>-7</sup>	9.8 x 10 <sup>-5</sup>	<b>-6.7</b>
SVOC	7.2 x 10 <sup>-9</sup>	1.1 x 10 <sup>-7</sup>	<b>-8.1</b>
Amines	not detectable <sup>2)</sup>	not detectable <sup>3)</sup>	--
Organophosphates	not detectable <sup>2)</sup>	not detectable <sup>3)</sup>	--
Siloxanes	not detectable <sup>2)</sup>	not detectable <sup>3)</sup>	--
Phthalates	not detectable <sup>2)</sup>	not detectable <sup>3)</sup>	--

<sup>1)</sup>SER<sub>a</sub>: Area-specific emission rate <sup>2)</sup>detection limit: 2.8 x 10<sup>-10</sup> <sup>3)</sup>detection limit: 1.7 x 10<sup>-9</sup>

ST 1902-1095  
Report No. first document

--  
Report No. current document

Stuttgart, February 28, 2019  
Place, date of first document issued

--  
Place, current date

on behalf of  
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.