



Nuplex Construction
Report No. NU 1310-671

Cleanroom[®] Suitable Materials

Sureshield
Microbicidity: very good

Flooring & Coating

DUPLICATE

Qualification Certificate

We hereby certify that the material stated above, provided by

Nuplex Construction Products
Christchurch, New Zealand

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number NU 1310-671.

Sureshield (Natural Gold; PR307706) was tested in accordance with CSM procedures of biological resistance. The tested material obtained the following classification.

Classification	Reduction factor R	CSM
<i>S. aureus</i>	> 3.3	very good
<i>E. coli</i>	> 5.4	excellent
Overall Result	> 3.3	very good

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, December 12, 2013

i. A. 
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.