



nora systems GmbH
Report No. NO 2302-1393

Cleanroom[®] Suitable Materials

noracare seneo
Biological Resistance: good

FLOORING & COATING

Single product Biological Resistance

Qualification Certificate

We hereby certify that the material stated above, provided by

nora systems GmbH
Weinheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number NO 2302-1393.

The biological resistance of noracare seneo (color: 7204) regarding to growth intensity was investigated in accordance with ISO 846 and classified with the following result:

Biological resistance	Growth intensity	Classification
Procedure A (resistance to fungi)	1	good
Procedure C (resistance to bacteria)	0	excellent
Overall result	good	

The classification is based on a worst-case consideration of the Procedures A and C.

NO 2302-1393
Report No. first document
--
Report No. current document

Stuttgart, May 17, 2023
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.