



StoCretec GmbH
Report No. ST 1902-1095

Cleanroom[®] Suitable Materials

StoFloor CR System 4
H₂O₂ Absorption/Desorption:
non-absorptive

FLOORING & COATING

Single product Hydrogen Peroxide Absorption/Desorption

Qualification Certificate

We hereby certify that the material stated above, provided by

StoCretec GmbH
Kriftel, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number ST 1902-1095.

The hydrogen peroxide absorption/desorption of StoFloor Cleanroom System 4 (StoPox WHG Deck 100), color: RAL 7032, was investigated at the stated test parameters, providing the following test result according to VDI 2083 Part 20:

Ø k-value [min]	Standard deviation [min]	Classification
2.3	0.3	non-absorptive

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

ST 1902-1095
Report No. first document
--
Report No. current document

Stuttgart, February 28, 2019
Place, date of first document issued
--
Place, current date

on behalf of
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA