



**StoCretec GmbH**  
**Report No. ST 1902-1095**

# Cleanroom<sup>®</sup> Suitable Materials

**StoFloor CR System 1**  
**Particle (vs. PA6): ISO 4**

## FLOORING & COATING

### Single product Particle Emission

DUPLICATE

### Qualification Certificate

We hereby certify that the material stated above, provided by

**StoCretec GmbH**  
 Kriftel, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number ST 1902-1095.

The level of particulate contamination emitted during application of tribological stress on the material pairing specified lies within the permissible values of the corresponding Air Cleanliness Class in accordance with ISO 14644-1:

Material pairing and test		Suitable for Air Cleanliness Class (ISO 14644-1)
StoFloor Cleanroom System 1 (StoPox BB OS) (color: RAL 7035)	vs. PA6	ISO Class: 4
Reel-on-disc test Normal force 300N		

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

ST 1902-1095  
 Report No. first document  
 --  
 Report No. current document

Stuttgart, May 28, 2019  
 Place, date of first document issued  
 --  
 Place, current date

on behalf of   
 Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA