



**Sika Deutschland GmbH**  
**Report No. SI 1611-861**

# Cleanroom<sup>®</sup> Suitable Materials

**Sikagard-Wallcoat N**  
**Particle (vs. PA6): ISO 6**

## FLOORING & COATING

### Particle Emission

### Qualification Certificate

DUPLICATE

We hereby certify that the material stated above, provided by

**Sika Deutschland GmbH**  
 Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1611-861.

The level of particulate contamination emitted during application of tribological stress on the material pairing specified lies within the permissible values of the corresponding Air Cleanliness Class in accordance with ISO 14644-1:

Material pairing and test		Suitable for Air Cleanliness Class (ISO 14644-1)
Sikagard-Wallcoat N (color: white)	vs. PA6	ISO Class: 6
Reel-on-disc test Normal force 300N		

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, March 16, 2017

on behalf of   
 Udo Gommel, Project manager Fraunhofer IPA

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.  
 Further information:  
[www.tested-device.com](http://www.tested-device.com).  
 Please visit [www.ipa-csm.com](http://www.ipa-csm.com).