



GERFLOR
Report No. GE 2203-1313

Cleanroom[®] Suitable Materials

MIPOLAM BIOCONTROL CLEAN
Chemical Resistance: very good

FLOORING & COATING

Single product Chemical Resistance

Qualification Certificate

We hereby certify that the material stated above, provided by

GERFLOR
Saint-Paul-Trois-Châteaux, France

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number GE 2203-1313.

The chemical resistance tests on MIPOLAM BIOCONTROL CLEAN (new varnish), color: intense Indigo, are performed in accordance with ISO 2812-1. Therefore the damages according to ISO 4628-1 and VDI 2083 Part 17 have been transferred to the following classification:

Chemicals	Chemical resistance	Chemicals	Chemical resistance
Formalin 37 %	excellent	Phosphoric acid 30 %	excellent
Ammoniac 25 %	excellent	Hydrochlorid acid 5 %	excellent
Isopropanol 100 %	weak	Hydrogen peroxide 10 %	excellent
Sulfuric acid 5 %	excellent	Sodium hydroxide 5 %	excellent
Peracetic acid 15 %	weak	Sodium hypochlorite 5 %	excellent

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

GE 2203-1313
Report No. first document
--
Report No. current document

Stuttgart, June 17, 2022
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA