



**GERFLOR**  
Report No. GE 2203-1313

# Cleanroom<sup>®</sup> Suitable Materials

**MIPOLAM BIOCONTROL CLEAN  
(smooth)**

**Riboflavin Test: excellent**

**FLOORING & COATING**

Single product  
**Riboflavin Test**

## Qualification Certificate

We hereby certify that the material stated above, provided by

**GERFLOR**  
Saint-Paul-Trois-Châteaux, France

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number GE 2203-1313.

The examination of cleanability of MIPOLAM BIOCONTROL CLEAN (new varnish), color: intense Indigo, was investigated according to VDMA information sheet. The following test result could be provided:

Material tested	Classification
MIPOLAM BIOCONTROL CLEAN (new varnish) (smooth)	<b>excellent</b>

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

DUPLICATE

GE 2203-1313  
Report No. first document

--  
Report No. current document

Stuttgart, June 17, 2022  
Place, date of first document issued

--  
Place, current date

on behalf of   
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA