



GERFLOR
Report No. GE 2203-1313

Cleanroom[®] Suitable Materials

MIPOLAM BIOCONTROL CLEAN
H₂O₂ Absorption/Desorption:
fast

FLOORING & COATING

Single product Hydrogen Peroxide Absorption/Desorption

Qualification Certificate

We hereby certify that the material stated above, provided by

GERFLOR
Saint-Paul-Trois-Châteaux, France

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number GE 2203-1313.

The hydrogen peroxide absorption/desorption of MIPOLAM BIOCONTROL CLEAN (new varnish), color: intense Indigo, was investigated at the stated test parameters, providing the following test result according to VDI 2083 Part 20:

Ø k-value [min]	Standard deviation [min]	Classification
14.8	0.54	fast

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

DUPLICATE

GE 2203-1313
Report No. first document

--
Report No. current document

Stuttgart, June 17, 2022
Place, date of first document issued

--
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA