



Cleanroom[®] Suitable Materials

GERFLOR
Report No. GE 1505-761

MIPOLAM BIOCONTROL EL5
Biol. Resistance: very good

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated above, provided by

GERFLOR
SAINT PAUL TROIS CHATEAUX, France

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number GE 1505-761.

MIPOLAM BIOCONTROL EL5 (light grey) was tested in accordance with CSM procedures of biological resistance. The tested material obtained the following classification:

	Test	Classification
Biological resistance (acc. to ISO 846)	Fungi (Procedure A)	ISO/CSM: 1/very good
	Bacteria (Procedure C)	ISO/CSM: 0/excellent
Overall result		ISO/CSM: 1/very good

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, August 13, 2015

i. A. 
Project manager

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.