



Fraunhofer

TESTED[®] DEVICE

Rockwool B.V., Rockfon
Medicare Block (prototype)
Report No. RO 1212-627

Qualification Certificate

This is to certify that the product mentioned above, provided by

Rockwool B.V., Rockfon
Roemond, The Netherlands

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number RO 1212-627.

The Medicare Block (prototype) ceiling system is suitable for use in cleanrooms fulfilling the Air Cleanliness Class 2 according to ISO 14644-1.

It must be pointed out, that cleanrooms classes 1 to 5 (according to ISO 14644-1) have a high number of filters, which makes the use of ceiling elements partly impossible. Cleanrooms with horizontal laminar flow are an exception.

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, March 8, 2013

i.A. 
Project manager

DUPLICATE

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:
www.tested-device.com