



# Cleanroom<sup>®</sup> Suitable Materials

Mapei S.p.A.  
Report No. MA 1502-748

MAPEFLOOR I306 CR  
Microbicidity: good

## Flooring & Coating

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Mapei S.p.A.**  
Milano, Italy

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number MA 1502-748.

The microbicidity tests on the MAPEFLOOR I306 CR (grey) are performed in accordance with ISO 22196. The tested material obtained the following classification.

Classification	Reduction factor R	CSM
<i>S. aureus</i>	2.0	good
<i>E. coli</i>	> 3.8	excellent
<b>Overall Result</b>	<b>2.0</b>	<b>good</b>

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on [www.tested-device.com](http://www.tested-device.com).

For more CSM information, please visit [www.ipa-csm.com](http://www.ipa-csm.com).

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, December 21, 2015

i. A.   
Project manager