



Fraunhofer

TESTED[®] DEVICE

Giroflex 63-3574
Report No. GI 0302-286

DUPLICATE

Qualification Certificate

This is to certify that the product mentioned below manufactured by the company

Giroflex Entwicklungs AG

CH-5322 Koblenz


has been awarded a Fraunhofer IPA Qualification Seal bearing the report number GI 0302-286.

The cleanroom swivel chair model »Giroflex 63-3574« is suitable for use in cleanrooms fulfilling the specifications of Air Cleanliness Class 5 (according to ISO 14644-1) and is suitable for use in EPA's (ESD-protected areas according to DIN EN 100 015-1).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report compiled by the Fraunhofer-Gesellschaft.

The duration of the validity of this certificate is unlimited. For further information visit our website at www.ipa-qualification.com.

Stuttgart, Germany, February 12, 2003

i. A. 
Project manager



Fraunhofer Institut
Produktionstechnik und
Automatisierung