



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

OWAlux 64/1/N

Report No. OW 0107-246

DUPLIKAT

### IPA Qualification Certificate

This is to certify that the product mentioned below manufactured by the company

**Odenwald Faserplattenwerk GmbH**

Dr.-Freundt-Strasse 3  
D-63916 Amorbach

has been awarded an IPA Qualification Seal bearing the report number OW 0107-246.

Due to the emission of particles, the OWAlux 64/1/N ceiling plates are suitable for use in cleanrooms fulfilling "Class 10" specifications (in accordance with US Federal Standard 209E).

Detailed information and parameters of the test environment can be found in the IPA Test Report compiled by the Fraunhofer Society.

Certified on 7<sup>th</sup> of September 2001.

The duration of the validity of this certificate is unlimited. Further information can be obtained from the web site <http://www.ipa-qualification.com>.

Stuttgart, Germany, 7<sup>th</sup> of September 2001

A handwritten signature in black ink, appearing to read 'Udo Gommel', written over a horizontal line.

Signature



Fraunhofer

Institut  
Produktionstechnik und  
Automatisierung