



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

OWAcoustic<sup>®</sup> Universal  
Report No. OW 0504-322

DUPLICATE

### IPA Qualification Certificate

This is to certify that the products mentioned below manufactured by the company

**Odenwald Faserplattenwerk GmbH**

Dr. Freundt-Str. 3  
D-63916 Amorbach

has been awarded an IPA Qualification Seal bearing the report number OW 0504-322.

Due to the emission of particles, the ceiling system OWAcoustic<sup>®</sup> Universal is suitable for use in cleanrooms fulfilling the specifications of the Air Cleanliness Class ISO Class 4 (according to ISO 14644-1). That is comparable with Class 10 according with US Federal Standard 209E and Class 2 according with VDI 2083 Part.

Detailed information and parameters of the test environment can be found in the IPA Test Report compiled by the Fraunhofer Society.

Certified on 4<sup>th</sup> April 2005.

The duration of the validity of this certificate is unlimited. For further information visit our website at <http://www.ipa-qualification.com>.

Stuttgart, Germany, 4<sup>th</sup> April 2005

A handwritten signature in black ink, appearing to read 'Udo Sommer'.

Signature



**Fraunhofer** Institut  
Produktionstechnik und  
Automatisierung