



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

Knauf AMF GmbH & Co. KG  
THERMATEX Thermofon/Plain  
**Report No. KN 0904-479**

DUPLICATE

## Qualification Certificate

This is to certify that the product mentioned below, by order of the company

**Knauf AMF GmbH & Co. KG**

Elsenthal 15  
D-94481 Grafenau

has been awarded a Fraunhofer-Certificate TESTED DEVICE bearing the report number KN 0904-479.


The ceiling system THERMATEX Plain is suitable for use in cleanrooms fulfilling air cleanliness specifications 7 according to ISO 14644-1.

On processing the material, the named test piece emits an increased level of particles. The cleanability of the surfaces must be adapted to the respective application.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The validity of this certificate applies only to the above mentioned product in this particular condition. For further information visit our website at [www.ipa-qualification.com](http://www.ipa-qualification.com).

Stuttgart, May 25, 2009

i. A.   
Project manager