



Fraunhofer

TESTED[®] DEVICE

StoCretec GmbH
StoPox WB 113
Report No. ST 0806-441-1

DUPLICATE

Qualification Certificate

This is to certify that the product mentioned below, manufactured by the company

StoCretec GmbH

Gutenbergstraße 6
65830 Kriftel
Germany

has been awarded an Fraunhofer IPA Qualification Seal, bearing the report number ST 0806-441-1.

The ECF flooring system StoPox WB 113 fulfils the specifications according to DIN EN 61340-4-1 and DIN EN 61340-5-1 and is suitable for unlimited use in EPA-controlled environments.

Resistance to ground	$2,4 \times 10^4 \Omega$
System resistance	$2,4 \times 10^6 \Omega$
Walkingtest body voltage (min/max)	- 0,47 V / +0,86 V

Detailed information and parameters of the test environment can be found in the Test Report compiled by the Fraunhofer-Gesellschaft.

Certified on 19th June 2008.

The duration of the validity of this certificate is unlimited.
For further information visit our website on www.ipa-qualification.com

Stuttgart, Germany, 19th June 2008

i. A.
Signature

A handwritten signature in black ink, appearing to read 'A. B. B.', written over a horizontal line.



Fraunhofer Institut
Produktionstechnik und
Automatisierung