



StoCretec GmbH
Report No. ST 0712-422

Cleanroom[®] Suitable Materials

StoPox WHG Deck 100

Particle: not tested

TVOC (23°C/90°C): ISO -6.6 / tested

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated below which was provided by

StoCretec GmbH

Gutenbergstr 6
 D-65830 Kriftel

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number ST 0712-422.

The tests performed in accordance with CSM procedures included outgassing at various temperatures and determination of the ESD value (surface resistance).

Material (Mat.)	StoPox WHG Deck 100	
Particle	Ball-on-disc test: -	not tested
Outgassing at 23°C / 73°F	TVOC	ISO-AMC Class -6.6 (see ISO 14644-8)
Outgassing at 90°C / 194°F	Amines Organo-phosphates Siloxanes Phthalates	0 x 10 ⁻⁹ g/m ² s 0 x 10 ⁻⁹ g/m ² s 0 x 10 ⁻⁹ g/m ² s 0 x 10 ⁻⁹ g/m ² s
ESD	Surface resistance	1.5 x 10 ¹⁰ Ohm

Detailed information regarding the test environment and parameters used can be obtained from the CSM Test report with the number ST 0712-422 issued by the Fraunhofer-Gesellschaft.

The validity of this certificate is indefinite. For more information, visit our website at www.ipa-csm.com.

Stuttgart, Germany, November 11th 2008

i. A. _____
 Signature project manager



Fraunhofer Institut
 Produktionstechnik und
 Automatisierung