



Sika AG  
Report No. SI 0908-494

# Cleanroom<sup>®</sup> Suitable Materials

Sikafloor-269 ECF CR  
Particle (vs. PA6): GMP A

## Flooring & Coating

DUPLICATE

### Qualification Certificate

We hereby certify that the material stated below which was provided by

**Sika Deutschland GmbH**

Kornwestheimerstraße 103-107  
D-70439 Stuttgart

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 0908-494.


The tests performed in accordance with CSM procedures included particle emission during the application of frictional stress. The tested material obtained following classification in accordance with the standard(s) listed below.

Material (Mat.)	Sikafloor-269 ECF CR	
Particle	Reel-on-disc test; Normal force 150 N Mat. vs. PA6	GMP Class A (see EC-GMP Annex 1, in operation)

Detailed information regarding the test environment and parameters used can be obtained from the CSM Test report number SI 0908-494 issued by the Fraunhofer-Gesellschaft.

The validity of this certificate is indefinite. For more information, visit our website at [www.ipa-csm.com](http://www.ipa-csm.com).

Stuttgart, Germany, August 24, 2009

i. A.   
Signature project manager



Fraunhofer Institut  
Produktionstechnik und  
Automatisierung