



Sika AG  
Report No. SI 0706-406

# Cleanroom<sup>®</sup> Suitable Materials

Sikafloor-266 CR  
Particle (vs. PA6): GMP A

## Flooring & Coating

DUPLICATE

### Qualification Certificate

We hereby certify that the material stated below which was provided by

**Sika Deutschland GmbH**

Kornwestheimerstraße 103-107  
D-70439 Stuttgart

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 0706-406.


The tests performed in accordance with CSM procedures included particle emission during the application of frictional stress.

Material (Mat.)	Sikafloor-266 CR	
Particle	Reel-on-disc test; Normal force 225 N Mat. vs. PA6	GMP Class A (see EG-GMP Annex 1)

Detailed information regarding the test environment and parameters used can be obtained from the CSM Test report number SI 0706-406 issued by the Fraunhofer-Gesellschaft.

The validity of this certificate is indefinite. For more information, visit our website at [www.ipa-csm.com](http://www.ipa-csm.com).

Stuttgart, Germany, July 15<sup>th</sup> 2009

i. A.   
Signature project manager



Fraunhofer Institut  
Produktionstechnik und  
Automatisierung