



Fraunhofer

TESTED[®] DEVICE

BUCK d.o.o.
CLEAN ROOM 414/840 DP
Report No. BU 1106-561

Qualification Certificate

This is to certify that the product mentioned above, provided by

BUCK d.o.o.
Belgrade, Serbia

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number BU 1106-561.

The luminaire CLEAN ROOM 414/840 DP is suitable for use in cleanrooms fulfilling the Air Cleanliness Class 1 according to ISO 14644-1.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, August 2, 2011

i.A. 
Project manager

DUPLICATE

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:
www.tested-device.com