



Cleanroom[®] Suitable Materials

Tarkett AB
Report No. TA 1108-567

iQ Optima
Particle (vs. PA6 Nylon): ISO 4

Flooring & Coating

DUPLICATE

Qualification Certificate

We hereby certify that the material stated above, provided by

Tarkett AB

372 73 Ronneby
Sweden


has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TA 1108-567.

The tests performed in accordance with CSM procedures included particle emission during the application of frictional stress. The tested material obtained the following classification in accordance with the standard listed below.

Material (Mat.)	iQ Optima	
Particle	Reel-on-disc test; Normal force 300N Mat. vs. PA6 Nylon	suitable for ISO Class 4 (see ISO 14644-1)

Detailed test information regarding the sample (serial number, color, batch number etc.), environment and parameters used, can be obtained from the CSM test report TA 1108-567 issued by the Fraunhofer-Gesellschaft.

Stuttgart, September 20, 2011

i. A. 
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified under www.tested-device.com

For more CSM information please visit: www.ipa-csm.com