



**Sika AG**  
**Report No. SI 1008-533**

# Cleanroom<sup>®</sup> Suitable Materials

**Sika-ComfortFloor Decorative**  
**Particle (vs. PA6): ISO 1**

## Flooring & Coating

DUPLICATE

### Qualification Certificate

We hereby certify that the material stated below which was provided by

**Sika Deutschland GmbH**

Kornwestheimerstraße 103-107  
70439 Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1008-533.

The tests performed in accordance with CSM procedures included particle emission during the application of frictional stress and outgassing at various temperatures. The tested material obtained following classification in accordance with the standard(s) listed below.

<b>Material (Mat.)</b>	Sika-ComfortFloor Decorative Wearing course: Sikafloor-300 N Seal coat: Sikafloor-304 W transparent	
<b>Particle</b>	Reel-on-disc test; Normal force 300 N; Mat. vs. PA6	ISO Class 1 (see ISO 14644-1)

Detailed test information regarding the sample (serial number, color, batch number, etc.), environment and parameters used, can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, May 11, 2011

i. A.  
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified under [www.tested-device.com](http://www.tested-device.com)

For more CSM information please visit: [www.ipa-csm.com](http://www.ipa-csm.com)