



Sika AG
Report No. SI 1108-568

Cleanroom[®] Suitable Materials

Sikafloor-326
Particle (vs. PA6): ISO 4

Flooring & Coating

DUPLICATE

Qualification Certificate

We hereby certify that the material stated below, provided by

Sika Deutschland GmbH
Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1108-568.


The tests are performed in accordance with CSM procedures included particle emission during the application of frictional stress. The tested material obtained following classification in accordance with the standard listed below.

| | | |
|------------------------|---|---|
| Material (Mat.) | Sikafloor-326, RAL 7035 | |
| Particle | Reel-on-disc test; Normal force 300N Mat. vs. PA6 | suitable for ISO Class 4 (see ISO 14644-1) |

The tested material was Sikafloor-326, RAL 7035. According to the manufacturer's specifications, there is no influence on the test results by the differing colors.

Detailed information regarding test environment and parameters used can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, February 28, 2012

i. A. 
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.