



nora systems GmbH
Report No. NO 1101-543

Cleanroom[®] Suitable Materials

noraplan sentica ed
Biol. Resistance: very good

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated above, provided by

nora systems GmbH
Weinheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number NO 1101-543.


The tests are performed in accordance with CSM procedures of biological resistance. The tested material obtained following classification in accordance with the standard listed below.

	Test	Classification
Biological Resistance (acc. to ISO 846)	Fungi (Procedure A)	ISO/CSM: 0/excellent
	Bacteria (Procedure C)	ISO/CSM: 1/very good
Overall result		ISO/CSM: 1/very good

The tested material was noraplan sentica ed recipe 948. According to the manufacturer's specifications, there is no influence on the test results by the differing colors.

Detailed information regarding test environment and parameters used can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, June 5, 2012; Date of first issuance: May 30, 2011

i. A. 
Project manager

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.