



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

OCTANORM  
Ceiling type D40\_1  
Report No. OC 1005-524

DUPLICATE

### Qualification Certificate

This is to certify that the product mentioned below provided by the company

#### OCTANORM-Vertriebs-GmbH für Bauelemente

Raiffeisenstraße 39  
70794 Filderstadt  
Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number OC 1005-524.


The Ceiling type D40\_1 is suitable for use in cleanrooms fulfilling the Air Cleanliness Class 4 according to ISO 14644-1.

The operation utility is herewith recommended for use in hygienic areas possessing a cleanliness level of GMP Cleanliness Class A. However, this only applies to the operating utility when in a resting state; an overall assessment of the production environment is required after installation of the utility.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The validity of this certificate applies only to the above mentioned product in this particular condition. For further information visit our website at [www.ipa-qualification.com](http://www.ipa-qualification.com).

Stuttgart, September 1, 2010

i. A.   
Project manager