



Fraunhofer

TESTED[®] DEVICE

OWA Faserplattenwerk GmbH
OWAtecta cleanRoom
Report No. OW 1105-554

Qualification Certificate

This is to certify that the product mentioned above provided by

Odenwald Faserplattenwerk GmbH
Amorbach, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number OW 1105-554.


The system OWAtecta cleanRoom is suitable for use in cleanrooms fulfilling the Air Cleanliness Class 4 according to ISO 14644-1.

A principle recommendation can be made for use in hygienic areas up to a maximum of GMP Cleanliness Class A. However, this only applies for the assessed operating utility in a resting state and the OWAtecta cleanRoom system L would need to be reassessed after assembly in a manufacturing environment.

A principle recommendation can be made for use in hygienic areas up to a maximum of GMP Cleanliness Class C. However, this only applies for the assessed operating utility in a resting state and the OWAtecta cleanRoom system U would need to be reassessed after assembly in a manufacturing environment.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, August 22, 2011

i. A. 
Project manager

DUPLICATE

The validity of this certificate applies only to the mentioned product in this particular condition.

Further information:
www.tested-device.com