



Fraunhofer

TESTED[®] DEVICE

Knauf Insulation GmbH
Heradesign soft
Report No. KN 1203-591

Qualification Certificate

This is to certify that the product mentioned above, provided by

Knauf Insulation GmbH
Ferndorf, Austria

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number KN 1203-591.

The ceiling system Heradesign soft is suitable for use in cleanrooms fulfilling the Air Cleanliness Class 5 according to ISO 14644-1.

It must be pointed out, that according to ISO 14644-1 cleanrooms classes 1 to 5 have a high number of filters, which makes the use of ceiling elements partly impossible. Cleanrooms with horizontal laminar flow are an exception.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, April 27, 2012

i.A. 
Project manager

DUPLICATE

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:
www.tested-device.com