



Sika AG
Report No. SI 1204-593

Cleanroom[®] Suitable Materials

Sikafloor-390 ECF
Particle (vs. PA6): GMP A

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated below, provided by

Sika AG
Stuttgart, Germany


has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1204-593.

Sikafloor-390 ECF, RAL 7035 was tested regarding particle emission during the application of frictional stress according to VDI 2083-17. The tested material obtained the following classification:

Material pairing and test		Suitable for Air Cleanliness Class (EU GMP Annex 1, in operation)
Sikafloor-390 ECF	vs. PA6	GMP Class: A
Reel-on-disc test Normal force 300N		

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, May 16, 2012

i. A. 
Project manager

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.