



Cleanroom[®] Suitable Materials

Sika AG
Report No. SI 1209-615

Sikafloor-701
Outgassing VOC (23°C/90°C):
ISO-AMC_m class -9.6 / tested

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated above, provided by

Sika AG
Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1209-615.


Sikafloor-701 (transparent) was tested regarding outgassing at various temperatures according to VDI 2083-17. The tested material obtained the following classification:

Test temperatures	Family of contaminants	Specific emission rate [g/m ² s]	ISO-AMC _m Class (x)
23°C / 73°F	VOC	2.8 x 10 ⁻¹⁰	-9.6
90°C / 194°F	Amines	not detectable	--
	Organo-phosphates	not detectable	--
	Siloxanes	not detectable	--
	Phthalates	not detectable	--

DUPLICATE

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, August 30, 2012

i. A. 
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.