



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

OCTANORM-Vertriebs-GmbH  
TPH 2 und DPH 1  
**Report No. OC 1312-679**

### Qualification Certificate

This is to certify that the product mentioned above, provided by

**OCTANORM-Vertriebs-GmbH**  
Filderstadt, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number OC 1312-679.

Both the wall as well as the ceiling system are principally recommended for use in hygienic environments up to max. GMP Cleanliness Class A. However, this only applies for the tested operating utility when in a resting state and an overall reassessment would need to be made after installation in a manufacturing environment.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, December 11, 2013

i.A.   
Project manager

DUPLICATE

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:  
[www.tested-device.com](http://www.tested-device.com)