



Cleanroom[®] Suitable Materials

ROHDE KG
Report No. RO 1310-674

Finish 435 FB
Microbicidity: excellent

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated above, provided by

ROHDE KG
Röttenbach, Germany


has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RO 1310-674.

Finish 435 FB (white) was tested in accordance with CSM procedures of biological resistance. The tested material obtained the following classification.

Classification	Reduction factor R	CSM
<i>S. aureus</i>	4.2	excellent
<i>E. coli</i>	> 6.8	excellent
Overall Result	4.2	excellent

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, January 9, 2014

i. A. 
Project manager

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.