

Sika Services AG  
Report No. SI 1501-752

# Cleanroom® Suitable Materials

Sikafloor-260 PurCem  
(smooth)  
Riboflavin test: excellent

## Flooring & Coating

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Sika Services AG**  
Pfäffikon, Switzerland

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1501-752.


Based on the VDMA information sheet »Riboflavin test for low-germ or sterile process technologies«, the ability to remove the fluorescent test contamination from the surface was tested by using a simple wiping process and ultra-pure water.

The classification to fluorescent residues is based on a worst-case consideration. Therefore the assessment according to ISO 4628-1 and VDI 2083-17 has been transferred to the following classification:

Material tested	Result
Sikafloor-260 PurCem (smooth)	0 = excellent

Detailed information regarding specific product data such as date of manufacture and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, April 22, 2015

i. A.   
Project manager

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on [www.tested-device.com](http://www.tested-device.com).

For more CSM information, please visit [www.ipa-csm.com](http://www.ipa-csm.com).