



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

Tarkett AB  
iQ Granit

**Report No. TA 1501-744**

### Qualification Certificate

This is to certify that the product mentioned above, provided by

**Tarkett AB**  
Ronneby, Sweden

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number TA 1501-744.

iQ Granit (color: 383|grey) was tested in accordance with procedures of biological resistance. The tested material obtained the following classification:

Biological resistance	ISO growth intensity	Classification
Fungi (Procedure A)	1	very good
Bacteria (Procedure C)	0	excellent
<b>Overall result</b>	1	very good

Biological resistance has been classified on the basis of a worst-case consideration of Procedures A and C. In the process, growth intensity was assessed according to the classification system used in ISO 846.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, April 9, 2015

i.A.   
Frank Bürger, Project manager Fraunhofer IPA

DUPLICATE

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:  
[www.tested-device.com](http://www.tested-device.com)