



# Cleanroom<sup>®</sup> Suitable Materials

Sika AG  
Report No. SI 1403-695

Sikafloor-21 PurCem  
Biol. Resistance: good

## Flooring & Coating

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Sika AG**  
Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1403-695.


Sikafloor-21 PurCem (RAL 7032) was tested in accordance with CSM procedures of biological resistance. The tested material obtained the following classification:

	Test	Classification
<b>Biological resistance</b> (acc. to ISO 846)	Fungi (Procedure A)	ISO/CSM: 1/very good
	Bacteria (Procedure C)	ISO/CSM: 2/good
<b>Overall result</b>		<b>ISO/CSM: 2/good</b>

DUPLICATE

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, August 7, 2014

i. A.   
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on [www.tested-device.com](http://www.tested-device.com).

For more CSM information, please visit [www.ipa-csm.com](http://www.ipa-csm.com).