



Roche Diagnostics GmbH  
Report No. RO 1608-841

# Cleanroom<sup>®</sup> Suitable Materials

MP2L joint seal (smooth)  
Riboflavin test: very good

## FLOORING & COATING

### Riboflavin Test

### Qualification Certificate

DUPLICATE

We hereby certify that the material stated above, provided by

**Roche Diagnostics GmbH**  
Mannheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RO 1608-841.

Based on the VDMA information sheet »Riboflavin test for low-germ or sterile process technologies«, the ability to remove the fluorescent test contamination from the surface was tested by using a simple wiping process and ultra-pure water.

The examination of cleanability of the MP2L joint seal was investigated according to VDMA information test sheet. The following test result could be provided:

Material tested	Classification
MP2L joint seal (smooth)	very good

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, November 30, 2016

on behalf of   
Udo Gommel, Project manager Fraunhofer IPA

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:  
[www.tested-device.com](http://www.tested-device.com).  
Please visit [www.ipa-csm.com](http://www.ipa-csm.com).