



Roche Diagnostics GmbH
Report No. RO 1608-852

Cleanroom[®] Suitable Materials

MP2L stoneware tile
Chemical Resistance: excellent

FLOORING & COATING

Chemical Resistance

Qualification Certificate

We hereby certify that the material stated above, provided by

Roche Diagnostics GmbH
Mannheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RO 1608-852.

The chemical resistance tests on the MP2L stoneware tile are performed in accordance with ISO 2812-1. Therefore the damages according to ISO 4628-1 and VDI 2083-17 have been transferred to the following classification:

Chemicals	Chemical Resistance	Chemicals	Chemical Resistance
Formalin 37 %	excellent	Phosphoric acid 30 %	excellent
Ammonia 25 %	excellent	Hydrochlorid acid 5 %	excellent
Isopropanol 100 %	excellent	Hydrogen peroxide 30 %	excellent
Sulfuric acid 5 %	excellent	Sodium hydroxide 5 %	excellent
Peracetic acid 15 %	excellent	Sodium hypochlorite 5 %	excellent

DUPLICATE

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, November 30, 2016

on behalf of 
Udo Gommel, Project manager Fraunhofer IPA

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:
www.tested-device.com.
Please visit www.ipa-csm.com.