



Cleanroom[®] Suitable Materials

Roche Diagnostics GmbH
Report No. RO 1608-853

PQ18 granite
Biol. Resistance: very good

FLOORING & COATING

Biological Resistance

Qualification Certificate

We hereby certify that the material stated above, provided by

Roche Diagnostics GmbH
Mannheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RO 1608-853.

The PQ18 granite was tested in accordance with CSM procedures of biological resistance. The tested material obtained the following classification according to ISO 846:

Biological resistance	Growth intensity	Classification
Fungi (Procedure A)	1	very good
Bacteria (Procedure C)	0	excellent
Overall result	1	very good

DUPLICATE

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:

www.tested-device.com.

Please visit www.ipa-csm.com.

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, November 30, 2016

on behalf of 
Udo Gommel, Project manager Fraunhofer IPA