



Cleanroom[®] Suitable Materials

Sika Deutschland GmbH
Report No. SI 1506-767

Sikafloor-305 W ESD
Biol. Resistance: very good

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated above, provided by

Sika Deutschland GmbH
Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1506-767.

Sikafloor-305 W ESD (RAL 7032) was tested in accordance with CSM procedures of biological resistance. The tested material obtained the following classification:

	Test	Classification
Biological resistance (acc. to ISO 846)	Fungi (Procedure A)	ISO/CSM: 0/excellent
	Bacteria (Procedure C)	ISO/CSM: 1/very good
Overall result		ISO/CSM: 1/very good

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, December 8, 2015

on behalf of 
Udo Gommel, Project manager Fraunhofer IPA